



HAZMAT  
Since 1985

# Functional Safety Certificate

As per IEC 61508-2:2010

*This is to certify that:*

**Compact™ Pneumatic Actuators models C15- C100**

**Manufactured by HABONIM Industrial Valves and Actuators**

Have been assessed by Hazmat LTD according to the requirements of IEC 61508-2:2010 and, when used under the conditions described in the attached document, are suitable to be part in safety functions up to and including:

Tag / Model	Continuous / high demand	Proof intervals must be less than:
C15, C20, C25, C30, C30M, C35, C35M, C45, C45M, C60, C60M, C75, C75M, C90M, C100, C100M, as S/R	SIL 2	5 years (as requested by manufacturer)
C15, C20, C25, C30, C30M, C35, C35M, C45, C45M, C60, C60M, C75, C75M, C90M, C100, C100M, as D/A	SIL 2	
Tag / Model	Low demand (confidence level)	Proof interval must be less than:
C15, C20, C25, C30, C30M, C35, C35M, C45, C45M, C60, C60M, C75, C75M, C90M, C100, C100M, as S/R	SIL 3	<i>Please refer to the complete report for advice on proof time intervals</i>
C15, C20, C25, C30, C30M, C35, C35M, C45, C45M, C60, C60M, C75, C75M, C90M, C100, C100M, as D/A	SIL 3	

Issue date: 31 January 2026

Valid until: 31 January 2031

Alexander

Signature

Certified by:

Dr. Alexander Cohen, CFSP  
Hazmat LTD, 24<sup>th</sup> Ha'Nagar St. Hod Ha'Sharon 4527713  
Israel, [www.hazamt.co.il](http://www.hazamt.co.il)  
Mail: [hazmat@hazmat.co.il](mailto:hazmat@hazmat.co.il)

This certificate does not waive the need to verify the safety integrity level (SIL) of the complete safety function

This certificate is valid until the date stated above and only when reproduced in its entirety without changes.

Certificate ID: 020128:3728-1-P1

